

Supervisor Field Check

Electrical & Extension-Cord Checks | v1.0 | October 6, 2026

Task / location: _____

Date / time / shift: _____ Leader: _____

JHA/JSA reference / revision: _____

Change or conditions confirmed unchanged: _____

Short leader check

Mark V = verified, H = hold/not verified, or N/A with a reason. Support each result with evidence below or a referenced task record; a blank is not a pass.

Check	V / H / N/A
Equipment, cord selection and supply arrangement suit the task and environment.	
Required visual checks found no unresolved defects; damaged items are isolated from use.	
Applicable GFCI protection or assured grounding program is identified for the covered circuits.	
Specified function check or traceable grounding test records are complete and acceptable.	
Cord routing, traffic, water and nearby electrical exposures are controlled.	

Control verification — attach more rows for all required controls

Control / exposure	Source, revision & criterion	Safe method / verifier	Actual result / time / status

Use applicable regulatory, manufacturer, procedure, permit or engineering criteria. Only appropriately competent and authorized people perform checks; do not improvise tests or enter danger to verify protection.

Unresolved item / restriction: _____

Action owner / due before exposure: _____

Correction / recheck result and time: _____

Stop contact: _____ Restart authority: _____

Next recheck trigger: _____ Crew rebrief completed: _____

Disposition: [] HOLD affected work [] Checks complete; required approval confirmed

Approval / permit reference or justified N/A: _____

Leader / date / time: _____

Unverified required protection means HOLD. Correct, recheck, obtain required site authorization and rebrief before exposure.

This sheet supports the task plan. It does not replace required permits, inspections, specialist decisions or employer authorization.